




SMS **GW**

Safety information

The device complies with regulations and industrial standards in force in the Czech Republic and the European Union. The device has been tested and is supplied in working order. To keep the device in this condition, it is necessary to adhere to the following safety and maintenance instructions.

Never remove the device cover if the relay terminals are connected to the electrical network!

Using the device in a manner other than prescribed by the manufacturer may cause its safeguards to fail!

The power supply outlet or disconnection point must be freely accessible.

The device must not be used in particular under any of the following conditions:

- The device is noticeably damaged
- The device does not function properly
- Unfastened parts can move inside the device
- The device has been exposed to moisture or rain
- The device has been serviced by unauthorized personnel
- The power adapter or power supply cable are noticeably damaged
- If the device is used in a manner other than designed for, the protection provided by the device may fail.
- The local electrical system must include a power switch or a circuit breaker and overcurrent protection.

The manufacturer warrants the device only if it is powered by the supplied power adapter or an approved power supply.

If you have any problems with installing or operating the device, please contact technical support:

HW group s.r.o.

<http://www.hw-group.com>

E-mail: support@HWg.cz

Phone: +420 222 511 918

Formanská 296

Prague, 149 00

Czech Republic


When contacting technical support, please keep at hand the exact type of your device (at the type plate) and, if possible, the firmware version (see later in this manual).

Table of contents

Safety information	2
Recommended connection	4
Technical parameters	5
Mechanical parameters	6
Restarting into the default settings (Load to defaults)	6
First start	7
Connecting the cables	7
IP address settings – HWg Config	7
Open the WEB setup of the device	8
WEB interface	9
Home	9
SMS Queue	10
General Setup	11
Time	12
GSM Modem	13
SNMP	14
System	15
Using SensDesk.com service	17
Using SMS gateway with Nagios	19
Installation	19
Nagios settings	20
Using the product with your application	22

Recommended connection

HWg-SMS-GW allows sending of alarm SMS messages from any number of connected HW group devices via a single GSM modem with netGSM.



Setting up HWg-SMS-GW3 with devices that support it:



- 1) Insert a SIM card.
- 2) Launch HWg Config and get the assigned IP address (DHCP).
- 3) Try to send a SMS from the web interface.



- 4) Enter IP address of the unit HWg-SMS-GW3 + port (80 in default).
- 5) Enter 2× phone number of an SMS messages recipient and try sending a test SMS.

Note: HWg-SMS-GW3 is compatible with the following devices: Damocles2, HWg-PWR, HWg-WLD, IP Watchdog2, Poseidon2, STE2, WLD2.

Technical parameters

Ethernet	
Interface	RJ45 (10BASE-T) – 10 Mbps or 10/100 Mbps network compatible
Supported protocols	IP: ARP, TCP/IP (http, NTP), UDP/IP (SNMP), netGSM
SNMP compatibility	Ver. 1.00 compatible, some parts of the ver. 2.0 implemented


GSM	
Interface	Quad-Band 850 / 900 / 1800 / 1900 MHz, Compliant to GSM phase 2/2+ Class 4 (2 W @ 850 / 900 MHz) Class 1 (1 W @ 1800 / 1900 MHz)
Antenna connector	SMA male

Power input	
Port	Power 9-30V DC
Type	Main device power input (typically 400 mA + external devices)
Connector	1× barrel jack (2.1mm, outer diameter 5.5 mm) 1× terminal block

LED status indicators	
Power	Green – power OK
Modem	Blue – activity on GPRS
Status	Yellow – blinking if device is OK
Alarm	Red – error on device
LINK & Activity	Yellow – ethernet connectivity

Physical parameters	
Temperature range	Operating: -10 to 65 °C / Storage: -25 to 85 °C
MTBF	> 90 000 hours
Dimensions / Weight	92×76×31 [mm] / 300 g
EMC	FCC Part 15, Class B, CE - EN 55022, EN 55024, EN 61000

Mechanical parameters



Restarting into the default settings (Load to defaults)

- *Restarting into the default settings via HWg Config* – right-click the MAC address of the device in HWg Config. Within the first 60 seconds after powering up the device the factory settings can be restored through HWg Config.

First start

Connecting the cables

- Note down the MAC address of the device, printed on the side of the unit.
- Connect HWg-SMS-GW to the Ethernet network.
- Plug the power adapter and connect it to a connector on the device.
- Green POWER LED will light up.
- If the connection to Ethernet network is working, LINK LED will light up (orange light on RJ45 connector) and it then flashes during the data transmission (Activity signalisation).

Connectors

- **Power** – connect the power adapter (9-30 V).
- **USB** – a connector for service purposes.
- **Ethernet** – network/data connector.
- **GSM SIM** – a SIM card socket.
- **GSM** – an SMA connector for connecting an external antenna.
- **Reset** – reset button for restoring the factory default settings.

LED indication

- **Power (green)** – power supply connected.
- **Status (yellow)** – flashes slowly if the device is working correctly.
- **Alarm (red)** – device / modem error. Lights up if out of signal, flashes in case of SIM card errors (incorrect PIN entered, etc.).
- **Modem (blue)** – flashes during SMS sending.
- **Link Activity (yellow LED on the Ethernet connector)** – flashes during network activity.
- **Link OK (green LED on the Ethernet connector)** – light on when connected to Ethernet.

IP address settings – HWg Config

The software *HWg-Config* can be downloaded from the HW Group website

- Start HWg -Config by clicking on its icon – software will automatically search for connected devices.
 - Search for the devices by clicking the Find Devices icon (Start search).
- HWg Config searches for devices in your LAN. Clicking on a MAC address of the device opens a window with basic network parameters settings.

Network parameters of the device


- DHCP is enabled by default.
- Set IP address / HTTP port (80).
- Set the mask of your network.
- Gateway IP address for the local network.

Save the settings with *Apply Changes* button.

Open the WEB setup of the device


Enter IP address of the device directly into an internet browser.

Or open the web setup via *HWg-Config*. Click the underlined IP address, or through the context menu (as shown on the picture).



WEB interface

Home



Base Information

- **Device name** – User-defined name. This can be set on the *General Setup* tab.
- **Time** – Unit time – settings can be changed on the *Time* tab. Correct time is usually obtained from an online server.
- **Date** – Unit date – settings can be changed on the *Time* tab. Correct date is usually obtained from an online server.
- **Network registration** – information on registration of the unit to an operator's GSM network.
- **Signal Quality** – GSM signal level. This information can be used for resolving network problems.
- **Operator Name** – name of the operator to which the GSM modem is connected.

SMS Queue

An overview of messages queued for sending. Sent messages are not shown here anymore.

- **ID** – ID of the outgoing message.
- **Phone Number** – recipient's phone number.
- **Type** – message type (SMS or dialing the number).
- **Retries** – number of unsuccessful retries.
- **Message** – message text.

SMS Queue

Displays the queues of incoming and outgoing messages. Messages already sent are not shown here.

HWg-SMS-GW3

HOME

SMS Input Queue

ID	Phone Number	Time	Message	Action
1	Usetreno.cz	06.06.2019 13:34:04	Topná sezona začína 1. 9. 2019. Overt e si, že nebudete platiť viac, než musít e na https://www.usetreno.cz/ene/	Delete
2	Erecept	11.06.2019 09:59:22	Identifikátor vašeho eReceptu vystave neho dne 11.6.2019 je PFEB KXUJ 6LD H a je platný do 25.6.2019. QR kód: https://erpid.info/erp?i=PFEBKXUJ6LDH&s=25.6.2019	Delete

[Input queue delete all entry](#)

SMS Output Queue

ID	Phone Number	Type	Retries	Message
----	--------------	------	---------	---------

Version: 1.1.15

HWg-SMS-GW3: For more information try www.hw-group.com

SMS Input Queue

Displays the incoming message queue.

- **ID** – ID of the incoming message.
- **Phone Number** – sender's phone number.
- **Time** – delivery time of the incoming message.
- **Message** – incoming message text.
- **Action** – the message can be deleted by pressing Delete.
- **Input queue delete all entry** – link to delete all queued incoming messages.

SMS Output Queue

Displays the outgoing message queue.

- **ID** – ID of the outgoing message.
- **Phone Number** – recipient's phone number.
- **Type** – message type (SMS or dialing the number).
- **Retries** – number of unsuccessful retries.
- **Message** – message text.

General Setup

HWg-SMS-GW3

192.168.100.169/general_setup.xml

Vyhledat

HWg-SMS-GW3 GENERAL SETUP

Base

Device Name: HWg-SMS-GW3 0 to 16 characters

WWW Info Text: HWg-SMS-GW3:For more information try www.hw-group.com

Network Setup

DHCP ☒ DHCP Enable/Disable

IP Address: 192.168.100.169 A.B.C.D

Network Mask: 255.255.252.0 A.B.C.D

Gateway: 192.168.100.1 A.B.C.D

DNS Primary: 192.168.100.237 A.B.C.D

DNS Secondary: 192.168.100.28 A.B.C.D

HTTP Port: 80 Default 80

WWW Security:

Username: Password: Username and password for device configuration [0 to 16 characters]

NetGSM (SOAP) security:

Username: Password: Username and password for NetGSM (SOAP) protocol - SMS and ringout sending

Version: 1.1.15

Apply Changes

HWg-SMS-GW3:For more information try www.hw-group.com

Base

- **Device Name** – Custom-selected name [HWg-SMS-GW3] – helps to distinguish between different HWg-SMS-GW3s in one network.
- **WWW Info Text** – text of a footer in WWW interface – useful for example for entering data centre administrator's contact details.

Network Setup

- **DHCP** – enables automatic setting of an IP address by a DHCP server, if available – enabling and disabling this function depends on actual requirements of the network users and administrators.
- **IP Address** – IP address of the HWg-SMS-GW3 – assigned by the network administrator.
- **Network Mask** – assigned by the network administrator.
- **Gateway** – IP address of a default gateway – assigned by the network administrator.
- **DNS Primary / DNS Secondary** – IP address of a DNS server – assigned by the network administrator.
- **HTTP Port** – port number where the built-in WWW server listens – changing the port number is necessary for example if more devices are accessible from outside the network through a router. Please consult any changes in this setting with your network administrator. Port set to 80 in default.

WWW Security

Username / Password – login details used for accessing HWg-SMS-GW3 settings.

NetGSM (SOAP) security

Username / Password – username and password for sending text messages over SOAP.

Time

The screenshot shows the HWg-SMS-GW3 web interface in a browser window. The address bar shows the URL `192.168.100.169/sntp.xml`. The page title is "HWg-SMS-GW3" and the sub-header is "TIME".

Current Time

Time:	10:15:11
Date:	26.06.2019

SNTP Setup

SNTP server address:	europe.pool.ntp.org	A.B.C.D. or Address Name
Interval:	1h	Sync period: Off/1h/24h
Summertime:	☒	last Sun Mar 2:00 - last Sun Oct 2:00
Time Zone:	1	Number 12 ... +13

Time Setup

Time:	10:15:08	hh:mm:ss
Date:	26.06.2019	DD:MM:YYYY

At the bottom of the page, it says: HWg-SMS-GW3: For more information try www.hw-group.com

Current Time

- **Time** – shows actual time.
- **Date** – shows actual date.

SNTP Setup

- **SNTP server address** – IP address or a domain address of a time server – in default time.nist.gov.
- **Interval** – interval of a time synchronisation with a server.
- **Summertime** – allows DST switching – required for correct logging of the measured values and events. Necessary for correct data logging.

- **Time Zone** – sets the time zone where the HWg-SMS-GW3 is located – used for setting the correct system time. Necessary for correct data logging.
- **Synchronize Time** – used for an immediate synchronisation with a time server. Can be also used to test the entered settings.

Time Setup

Time Setup section allows you to enter actual time and date manually, in case you cannot use the synchronisation with a time server. This information is erased after loosing the power supply.

GSM Modem

HWg-SMS-GW3

192.168.100.169/modem.xml

Vyhledat

HWg-SMS-GW3 GSM MODEM

Information

Network Registration:	Registered, home network
Signal Quality:	-67 dBm (74 %)
Operator Name:	T-Mobile CZ
SMS Service Center Address:	+420603052000
Number of SMS:	3792
Number of failures SMS:	1
Number of Ringout:	1239
Number of failures Ringout:	0

Clear counters

Configuration

SIM Pin:

Roaming Enable: ☒ Allow users to send SMS even when home network is not available

SMS http GET Enable: ☐ Enable http GET API

Manual Network: ☐ Manual Set Network enable/disable

Test SMS

Tel Number:

Text:

Send SMS Test

Ringout Test

version: 1.1.15

Apply Changes

HWg-SMS-GW3: For more information try www.hw-group.com

Information

- **Network registration** – information on registration of the unit to an operator's GSM network.
- **Signal Quality** – GSM signal level. This information can be used for resolving network problems.
- **Operator Name** – name of the operator to which the GSM modem is connected.
- **SMS Service Center Address** – information obtained from the SIM card. Used for verifying the communication with the SMS centre
- **Number of SMS** – number of messages sent.

- **Number of failures SMS** – number of unsent messages (invalid phone number etc.).
- **Number of Ringout** – number of dialed calls.
- **Number of failures Ringout** – number of unsuccessfully dialed calls (invalid phone number etc.).

Configuration

- **SIM PIN** – if the SIM is protected with a PIN, enter it here.
- **Roaming enable** – enables or disables SMS-GW3 operation in roaming. With roaming disabled, the gateway only works in the home carrier's network; this avoids undesired roaming costs. Enabled roaming may increase stability e.g. near country borders.
- **SMS http GET Enable** – enables the sending of SMS over HTTP GET. Using HTTP GET is a security risk, consider it carefully.

For details, see: <https://www.hw-group.com/support/how-to-send-sms-via-hwg-sms-gw3>

- **Manual network** – allows manual selection of the mobile network to use.

Test SMS

- **Tel Number** – test message recipient's phone number.
- **Text** – test message text.
- **Send SMS Test** – button to send a test SMS to the specified phone number.
- **Ringout Test** – button to try to dial the specified phone number.

SNMP

HWg-SMS-GW3 SNMP

General SNMP Settings

System Name: 0 to 16 characters

System Location: 0 to 16 characters

System Contact: 0 to 48 characters

SNMP port: Default 161

SNMP Access

Community	Read	Write	Enable
public	☒	☐	☒
private	☒	☒	☒

[Show OID keys table](#)

Version: 1.1.15

HWg SMS GW3:For more information try www.hw-group.com

General SNMP Settings

- **System Name** – device name, corresponds with the device name set on the *General setup* tab.
- **System Location** – system location, for instance „IT room, 2nd floor“.
- **System Contact** – system administrator contact details, for instance his email address.
- **SNMP port** – port settings for communication with SNMP protocol [161].

SNMP Access

Defines authorisation and user group names for work with a Poseidon device.

- **Community** – text name of the group, to which the rights are assigned to (Public and Private in default).
- **Read** – assigns to a community the rights to read the variables over SNMP.
- **Write** – assigns to a community the rights to write into the variables over SNMP.
- **Enable** – enables or disables a certain group.
- **Show OID keys table** – lists all available SNMP OIDs including their use.

System

System tab offers access to main system details such as uptime and firmware version. It also offers restart options or tools for firmware update.

The screenshot displays the web interface of the HWg-SMS-GW3 device. The browser address bar shows the URL `192.168.100.169/system.xml`. The interface has a purple theme. On the left is a sidebar with navigation links: Home, SMS Queue, General Setup, Time, GSM Modem, and SNMP. The 'System' link is highlighted, and below it, the version '1.1.15' is shown with an 'Apply Changes' button. The main content area is titled 'HWg-SMS-GW3 SYSTEM'. It contains several sections: 'Download' with links for Backup bin configuration (SMS_GW3_Config.bin), Backup xml configuration (setup.xml), Online status in XML (status.xml), and SNMP MIB Table (HWg-SMS_GW3.mib); 'Syslog' with a Syslog server IP address field set to '0.0.0.0' and a note 'A.B.C.D, 0.0.0.0 = Syslog disabled'; 'System' details including Product Name (HWg-SMS-GW3), Serial Number (6006390259), MAC Address (00:0A:59:04:5F:26), Modem IMEI (060325021309267), Version (1.1.15), Build (1963), Compile time (Jan 2 2018, 09:03:05), UpTime (1344100 [s]), Demo Mode (Demo Mode), Read available version (---), and Start Network Upgrade (---). At the bottom of this section are buttons for 'Upload Firmware or Configuration' (Procházet..., Soubor novybrán., Upload) and 'Factory Default' (Default, System Restart). A footer note says 'HWg-SMS-GW3: For more information try www.hw-group.com'.

Download

- [Backup bin configuration](#) – by clicking the link you can save the actual HWg-SMS-GW3 configuration and later restore this configuration.
- [Backup xml configuration](#) – by clicking the link you can save the actual HWg-SMS-GW3 configuration and later restore this configuration.
- [Online status in XML](#) – current device state in XML format.
- [SNMP MIB Table](#) – SNMP MIB file – address of a MIB file, containing definition of SNMP variables.

Syslog

[Syslog server IP Address](#) – address of the Syslog server.

System

- [Product Name](#) – name (type) of the device.
- [Serial Number](#) – device's serial number.
- [MAC Address](#) – device's MAC address for wired connections.
- [Modem IMEI](#) – IMEI address of the modem for GSM connection.
- [Version](#) – firmware version. Diagnostic information for troubleshooting.
- [Build](#) – assembly diagnostic information for troubleshooting.
- [Compile time](#) – firmware compilation time. Diagnostic information for troubleshooting.
- [UpTime](#) – uptime since last power-on or reset of the device. Diagnostic information for troubleshooting.
- [Demo mode](#) – activated demo mode disables changes in configuration of your device. Visitors can freely browse all pages of the WWW interface in this mode but they cannot make any changes. The device can be then made available on a public network without any risk of problems with settings.
- [Read available version](#) – displays the latest firmware version available at the HW group upgrade server.
- [Start Network Upgrade](#) – initiates firmware upgrade from the HW group upgrade server.
- [Upload Firmware or Configuration](#) – allows users to upload new firmware or a configuration file. Uploaded configuration may not be compatible in case the difference between firmware releases is too large.

Factory Default

Restores the factory default settings. The default IP address is 192.168.10.20 and both login and password are not set.

System Restart

Resets the device.

Using SensDesk.com service

SensDesk.com service is an online portal for HW group IP sensors monitoring. SensDesk.com can send email notifications in case an alarm is detected. HWg-SMS-GW3 can be used for sending SMS notifications.

- 1 Set IP address of your HWg-SMS-GW in the account settings:
[SensDesk.com: My Account >> Edit](#)

The screenshot displays the 'My account' settings page on the SensDesk.com portal. The page is titled 'My account' and includes a navigation bar with links for 'View', 'Edit', and 'Roles'. The main content area is divided into several sections:

- TEAM**: A dropdown menu showing 'Team HW group (ID: 213)'.
- SENDESK PORTAL CONFIGURATION**:
 - Default recipient for Simple SMS alarm**: A text input field.
 - Default gateway for Simple SMS alarm**: A text input field containing 'http://192.168.100.169/'. Below it, a note states: 'Fill in address in format http://domain.com:80/service.xml'.
- LOGIN**:
 - E-mail address**: A text input field containing 'demo@hwg.cz'. Below it, a note states: 'A valid e-mail address. All e-mails from the system will be sent to this address. The e-mail address is not made public and will only be used if you wish to receive a new password or wish to receive certain news or notifications by e-mail.'
 - Password**: A text input field with a 'Password strength' indicator.
 - Confirm password**: A text input field.
 - Roles**: A list of roles with checkboxes: 'UM: Team admin' (checked), 'UM: Device admin', 'UM: Report admin', and 'UM: Visitor'. Below the list, a note states: 'Change roles assigned to user.'
- EMAIL SETTINGS**: A section with a checkbox for 'Plaintext email only' and a note: 'Check this option if you do not wish to receive email messages with graphics and styles.'
- COUNTRY**: A dropdown menu showing 'Austria'.

- 2 Set the recipient phone number for each single sensor, for sending alarm SMS messages from: [SensDesk.com: Sensors >> Edit](#)

SensDesk
IOT PORTAL BY HW GROUP

Home » Sensors

Edit Sensor 2594 (in SensDesk)

View Edit Delete Alarms

SensDesk unique sensor ID
188146

Current value
32 %RH

Sensor value usage (in SensDesk)
Enabled

State of sensor
✓

Local sensor name (in the device)
Sensor 2594

Sensors name (in SensDesk)
Sensor 2594

SD SafeRange *
30 to 80
Sending alarm if value out of this range.

Hysteresis *
10

Calibration (shift) *
0

Custom decimal places

Description

Email & SMS alerts
* Sends an alert to all pre-set SMS and e-mail recipients when exceeding the "SD SafeRange" and even after returning to the safe range.

Active	Alarm module	Recipient	Gateway	Delete
☒	Simple e-mail alarm			
☒	Simple SMS GW alarm		http://192.168.100.169/	
☒	Simple set output alarm			

[Add my Simple e-mail alarm](#) [Add my Simple SMS GW alarm](#) [Add my Simple set output alarm](#)

[Save](#)

HW group
SensDesk.com is free online portal for LAN and GSM sensors from HW group.
HW group s. r. o. | Rumunská 26, 120 00 Prague | Phone: 222 511 918 | Fax: 222 513 833


© HW group 2019

Note: HWg-SMS-GW3 must be accessible on a public IP address in order to send SMS alarms from your SensDesk.com account.

Using SMS gateway with Nagios

Sending notifications from Nagios using SMS gateway HWg-SMS-GW3.

A plug-in for HWg-SMS-GW3, created in cooperation with Netways, allows sending SMS messages from Nagios system.



Nagios plug-in `notify-poseidon-sms.pl` takes notifications about changes on the monitored devices and transfers them via HTTP protocol to HWg-SMS-GW, which then sends an SMS message.

Installation

The following steps are based on standard Ubuntu server installation process. Some folders or commands can vary due to different Linux distribution used.

- 1 Download the `notify-poseidon-sms.pl` plug-in from <https://www.netways.org/projects/plugins/files> do adresáře `/usr/lib/nagios` and set the setup rights.

```
nagios-server:~# cd /usr/lib/nagios
nagios-server:~# wget https://www.netways.org/attachments/download/262/notify-poseidon-sms.pl
nagios-server:~# chmod a+x notify-poseidon-sms.pl
```

- 2 Send a test SMS to verify the functions of the plug-in and HWg-SMS-GW3. Parameter -H specifies an IP address of the HWg-SMS-GW3 device designated for sending the SMS messages. Enter the recipients phone number for receiving the message using the -D parameter.

```
nagios-server:~# cd /usr/lib/nagios
nagios-server:~# ./notify-poseidon-sms.pl -M "Test message" -H 192.168.1.1 -D +42077888999
```

In case the plug-in start fails and an error message shows Can't locate LWP.pm, it is necessary to install a Perl module LWP for HTTP protocol support. This can be done on Ubuntu or Debian by a command:

```
nagios-server:~# apt-get install libio-all-lwp-perl
```

Nagios settings

Document recommended for basic Nagios setup:

<https://www.hw-group.com/support/how-to-send-sms-via-hwg-sms-gw3>

- 1 A support for sending SMS messages with the notify-poseidon-sms.pl plug-in can be added by creating a file /etc/nagios3/notify-poseidon-sms.cfg:

```
define command {
command_name notify-host-by-sms
command_line /usr/bin/perl /usr/lib/nagios/notify-poseidon-sms.pl -H 192.168.1.1 -D
$CONTACTPAGER$ -M "$HOSTALIAS$ $HOSTOUTPUT$"
}
define command {
command_name notify-service-by-sms
command_line /usr/bin/perl /usr/lib/nagios/notify-poseidon-sms.pl -H 192.168.1.1 -D
$CONTACTPAGER$ -M "$HOSTALIAS$ $SERVICEOUTPUT$"
}
```

Note: The whole `command_line` definition text has to be in one line in order to work correctly.

Note, do not forget to change the -H parameter to an actual IP address (eventually to a DNS name) of your HWg-SMS-GW device.

SMS text is assembled by the -M parameter. A list of supported variables (macros) can be found on http://nagios.sourceforge.net/docs/3_0/macrolist.html

- 2 Define contacts and contact groups for SMS messaging in a file:
`/etc/nagios3/conf.d/contacts_nagios.cfg`.

```

define contact {
    contact_name           peter-gsm
    alias                  Peters GSM phone
    service_notification_period 24x7
    host_notification_period 24x7
    service_notification_options w,u,c,r
    host_notification_options d,r
    service_notification_commands notify-service-by-sms
    host_notification_commands notify-host-by-sms
    pager                  +420777888999
}

define contactgroup {
    contactgroup_name      sms
    alias                  Notifications via SMS
    members                 peter-gsm
}

```

Note: In case you want to send notifications to multiple phone numbers, create a contact for every phone number and enter each contact into a members parameters in a contactgroup (divided with ,).

In case you are using a standard Nagios configuration and want to add SMS sending for all devices and services, do not create a contactgroup and add only peter-gsm to the admins group. The setup is then complete and the notifications will be sent also via SMS after restarting the Nagios service (points 3 and 4).

```

define contactgroup {
    contactgroup_name      admins
    alias                  Nagios Administrators
    members                 root, peter-gsm
}

```

- 3 Adding SMS notification options to selected devices and services can be done in their definition, by adding a `contact_groups` parameter, for example:

```
define host {
    use                generic-host
    host_name          localhost
    alias              localhost
    address            127.0.0.1
    contact_groups     admins,sms
}
define service {
    use                generic-service
    host_name          localhost
    service_description Disk Space
    check_command      check_all_disks!20%!10%
    contact_groups     admins,sms
}
```

Note: Contacts are usually defined in the device's or service's templates, adding `contact_groups` parameters will rewrite the pre-set template. This example is based in a standard settings of an `admins` contact group, which uses e-mails for sending notifications. Only SMS messages will be sent after adding "contact_groups sms" parameter.

- 4 A restart of Nagios needed to activate the changes.

```
nagios-server:~# service nagios3 restart
```

Using the product with your application

HWg-SMS-GW communicates over LAN via a netGSM protocol built on HTTP. In case you want to use this product with your application, use the HWg-SDK (Software Development Kit). The SDK kit contains commented examples of the source codes for various programming languages.



<https://www.hw-group.com/product-version/netgsm>

<https://www.hw-group.com/support/netgsm-how-does-it-work-with-hw-group-devices>

Other HW group devices from Monitoring category



Poseidon2 3266/3268

The basic unit for monitoring temperature, humidity and other environmental conditions across LAN.



Poseidon2 2468

Remote monitoring of temperature, humidity and other environmental conditions in industrial design.



Poseidon2 4002

Unit designed for demanding monitoring applications, e.g. in data centers and industry.



Damocles2 2404

Secure industrial I/O with PoE and telco -48V power options.



HWg-WLD

Unit for detecting flooding with detection over the entire length of the sensing cable.



HWg-PWR 3/12/25

Measures power consumption using external M-Bus meters.

